



INDIA HOLDINGS PVT. LTD.

OFFICE: 101, TROMBAY ROAD, CHEMBUR,
MUMBAI-400 088. TEL.:25564001 • FAX NO. 25565148

Date Tuesday, March 11, 2008

To,
MANOR ENTERPRISES
180 Ratna Deep Navi Peth.
L.B.Shastrri Road,
Pune-411 030

Kind Attn:- Shri Shekhar Kulkarni.

Sub:- Letter of Installation for Desuperheater Waste Heat Recovery System.

We would like to express our full satisfaction for the Waste Heat Recovery Desuperheater Hot water system installed on our 100 TR Kiriloskar KC-6 Compressor at our refrigeration plant for last 4 months.

We are very happy with innovative product Developed by M/S. Manor Enterprises. The product is in line Pepsi' worldwide commitment towards Energy saving.

The design has unique advantage of easy accessibility for on line cleaning. Under guidance of our engineering team M/S. Manor Enterprises executed complete project without disturbing our production schedule.

We have achieved following results

Water Inlet Temperature 30°C
Hot Water Outlet Temperature 60°C

Lower head pressure of compressor reducing wear and tear expenses, better condenser efficiency and reduced power consumption of refrigeration compressor are additional benefits.


Manoj Dande.

MFG. Manager

Date : 08.03.2008

To
Manor Enterprises
"Ratnadeep", 180 Navi Peth,
Pune 411 030

Subject : Letter of Appreciation for Desuperheater Water Heater


Dear Sir,

We would like to express our full satisfaction & appreciation for the Waste Heat Recovery Desuperheater Water Heater installed on our KC-G Compressors by you.

With Desuperheater we have achieved the The 16° DT For 2000 Cub mtr flow.

We are very happy & satisfied with the performance of the Desuperheater & wish you all the Bests.

Thanking you.



FOR PEPSICO INDIA HOLDING PVT. LTD.
Sushil Garg
AUTHORISED SIGNATORY



VARUN BEVERAGES LTD.

Factory : Plot No. 2, Surajpur By Pass, Greater Noida- 201 306 (U.P.) 0120 - 4600300, 4600350, Fax : 0120-4600349

Date: - 26th March 2010

TO WHOM SO IT MAY CONCERN

Letter of Appreciation for Desuperheater Water Heater

We would like to express our full satisfaction for the West Heat Recovery Desuperheater Free Hot Water System Installed on our 112 TR Kirloskar KC-6 Compressor at our Refrigeration Plant for Last One Year.

We are very happy with innovative product Developed by M/s Manor Enterprises (Pune) the product is in line Pepsi' worldwide commitment towards "Energy Saving".

The design has unique advantage of easy accessibility for on line cleaning. Under guidance of our engineering team M/s Manor Enterprises executed complete without disturbing our production schedule.

Manoj Kumar Singh
MM

Varun Beverages Limited
Greater Noida (U.P)



ARADHANA SOFT DRINKS COMPANY

(A Subsidiary of Pepsico India Holding Pvt. Ltd.)

VILL. ALI ASGARPUR , P. O . GANJBAR, G. T. ROAD, PANIPAT - 132103 (HARYANA)
PHONE : 0180-2576309-310, 2576611, FAX : 91-180-257622

Date: - 27th March 2010

TO WHOM SO IT MAY CONCERN

Letter of Appreciation for Desuperheater Water Heater

We would like to express our full satisfaction for the West Heat Recovery Desuperheater Free Hot Water System Installed on our 112 TR Kirloskar KC-6 Compressor at our Refrigeration Plant for Last One Year.

We are very happy with innovative product Developed by M/s Manor Enterprises (Pune) the product is in line Pepsi' worldwide commitment towards "Energy Saving".

The design has unique advantage of easy accessibility for on line cleaning. Under guidance of our engineering team M/s Manor Enterprises executed complete without disturbing our production schedule.

We have achieved following results.

Water Inlet Temperature	30°C
Water Outlet Temperature	65°C
Gas Inlet Temperature	95 TO 100°C
Gas Outlet Temperature	65 TO 68°C
Water Flow	1500Ltr. /Hr
Savings in Steam	400 kg/hr.

Lower head pressure of compressor reducing wear and tear expenses, better condenser efficiency and reduced power consumption of refrigeration compressor are additional benefits.

Rahul Gupta

Asst. Manager (Maintenance)
Pepsi - Panipat